



SUCCESS BY QUALITY

Entwicklungs- und Prüflabor Holztechnologie GmbH
Zellescher Weg 24 · 01217 Dresden · Germany
www.eph-dresden.de



Deutsche
Akkreditierungsstelle
D-PL-11054-01-00


accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

TEST CERTIFICATE


CT-22-11-15-01

- Products:** Laminate flooring acc. to EN 13329
Thickness: 7 – 12 mm
- Producer:** Kronospan KO Sp. z. o. o.
ul. 1 Maja 52
47-100 Strzelce Opolskie
Poland
- Order:** Emission measurement regarding VOC and Formaldehyde
according to French VOC-Regulation “Arrêté étiquetage”
- Methods:** ISO 16000 parts 3, 6 and 9, DIN EN 16516
- Test Reports:** 2522385/1/A1, /2, 3/A1 and /4 dated 15/11/2022
- Test Results:** The tested laminate floorings fulfil the emission class A+ according
to French VOC-Regulation “Arrêté étiquetage” after 28 days.

Dresden, 15/11/2022


Head of laboratory




Engineer in charge