

T E S T C E R T I F I C A T E

ST-22-09-20-04


- Products:** "Laminate flooring collection, level of use 33 / AC6"
Thickness: 8 mm - 12 mm
- Producer:** Kronospan KO Sp. z. o. o.
ul. 1 Maja 52
47-100 Strzelce Opolskie
Poland
- Order:** Determination of selected properties
according to EN 13329:2016+A2:2021-09
- Test report:** 2722246/1
- Test results:** The general requirements according to EN 13329:2016+A2:2021-09, Table 1 are fulfilled. The classification requirements according to EN 13329:2016+A2:2021-09, Table 2 of the following classes are fulfilled:
- | | |
|---|-------------------------|
| Resistance against abrasion: | classes 21-23 and 31-34 |
| Resistance against impact small ball: | classes 21-23 and 31-33 |
| Resistance against impact big ball: | classes 21-23 and 31-33 |
| Resistance against staining: | classes 21-23 and 31-34 |
| Resistance against movement of a furniture leg: | classes 21-23 and 31-34 |
| Resistance against soft chair rolls: | classes 21-23 and 31-33 |
| Thickness swelling: | classes 21-23 and 31-33 |
| Locking strength short side joints: | classes 21-23 and 31-34 |
| Locking strength long side joints: | classes 21-23 and 31-34 |
| Surface soundness: | classes 21-23 and 31-34 |

Dresden, 20/09/2022



Head of laboratory





Engineer in charge